

**Date:** June 3, 2025

**To:** Steve Petersen  
Campus Architect  
William Rainey Harper College  
1200 West Algonquin Road  
Palatine, Illinois 60067-7398

**Re:** Harper College  
Building Z  
Electrical Reels  
GBA #P25-0043-00

This Addendum forms a part of the Bidding Documents and amends the original documents dated May 20<sup>th</sup>, 2025.

Acknowledge receipt of this addendum in the space provided on Bid Form. Failure to do so may subject bidder to disqualification.

## DRAWINGS

---

### **E400** (issued)

1. Revise (16) circuit breakers in Panel ZP1A, feeding power cord reels to GFCI type.
2. Revise (8) circuit breakers in Panel ZP1C, feeding power cord reels to GFCI type.

## PROJECT MANUAL AND SPECIFICATIONS

---

### **SECTION 00 3000 BID FORM** (issued)

1. Revise Substantial Completion Date and Final Completion Date of CONTRACT TIME to: Tuesday, January 6, 2026

### **SECTION 00 5200 STANDARD FORM OF AGREEMENT BETWEEN OWNER AND CONTRACTOR** (issued)

1. In A101 document (section 3.3 substantial completion), revise the Substantial Completion Date to: January 6, 2026.
2. In A201 document (section 1.1.1 the contract documents), revise the Contract Document Date to May 20, 2025.

### **SECTION 01 1100 SUMMARY OF WORK** (issued)

1. Revise Section 1.5 work sequence of spec section 011100 to indicate a completion date of January 6, 2026

END ADDENDUM